



DATE: May 14, 2020 WQ 0.10.14.4

TO: Oregon Health Authority, Drinking Water Services

**SUBJECT: Monthly Report for April 2020
Bilateral Compliance Agreement
Intake *Cryptosporidium* Results
PWS # 4100657**

To Whom It May Concern:

Enclosed are results of laboratory analyses for *Cryptosporidium* from the Bull Run raw water intake for April. Monitoring for *Cryptosporidium* at the Bull Run intake is done to comply with the interim measures of the Bilateral Compliance Agreement (Oregon Health Authority, December 18, 2017).

Analyses for *Cryptosporidium* and *Giardia* were performed by the PWB Laboratory (see attached report). Also attached are copies of the monthly turbidity and raw coliform reports previously submitted to OHA in compliance with the SWTR. Results for the reporting month are summarized below:

***Cryptosporidium*, *Giardia*, Turbidity and Fecal Coliforms Data Summary for the Reporting Month**

<i>Cryptosporidium</i> and <i>Giardia</i> Field Samples				<i>Cryptosporidium</i> Recoveries		Fecal Coliforms	Turbidity
No. of Samples	Total Volume (L)	Total No. <i>Cryptosporidium</i> Oocysts	Total No. <i>Giardia</i> Cysts	No. of Matrix Spikes	Average Matrix Spike Recovery (%)	Highest Count (CFU/100 mL)	Highest Reading (NTU)
15	750	2	2	1	73.7	1	0.39

If you have any questions regarding these results, please contact me at 503-823-6135.

Sincerely,



Ann Levy
Senior Environmental Program Manager



Portland Water Bureau Laboratory
2010 N Interstate Ave, Portland, OR 97227

Cryptosporidium and Giardia Laboratory Analysis Report

<u>Water System Information</u>			<u>Sample Information</u>		
PWS ID:	OR4100657		Collection Month & Year:	April 2020	
PWS Name:	Portland Water Bureau 1900 N Interstate Avenue Portland, Oregon 97227		Report Date:	May 5, 2020	
County:	Multnomah		Monitoring Regime:	Bilateral Compliance Agreement	
			Source Water:	Bull Run Intake - WTP-A	

PWB Sample ID	Loc ID	Sample Collection Date	Sample Type	Sample Volume Filtered (L)	Analysis Method	<u>Cryptosporidium</u>			<u>Giardia</u>		
						No. of Oocysts Spiked	No. of Oocysts Counted	Oocyst Matrix Spike Recovery (%)	No. of Cysts Spiked	No. of Cysts Counted	Cyst Matrix Spike Recovery (%)
BC36509	Intake 2PIS	4/1/2020	Field	50.0	1623.1	0	0		0	2	
BC36755	Intake 2PIS	4/5/2020	Field	50.0	1623.1	0	0		0	0	
BC36756	Intake 2PIS	4/6/2020	Field	50.0	1623.1	0	0		0	0	
BC36757	Intake 2PIS	4/7/2020	Field	50.0	1623.1	0	0		0	0	
BC36758	Intake 2PIS	4/8/2020	Field	50.0	1623.1	0	0		0	0	
BC37013	Intake 2PIS	4/12/2020	Field	50.0	1623.1	0	0		0	0	
BC37014	Intake 2PIS	4/13/2020	Field	50.0	1623.1	0	0		0	0	
BC37015	Intake 2PIS	4/13/2020	MS	50.5	1623.1	99	73	73.7	99	83	83.8
BC37016	Intake 2PIS	4/14/2020	Field	50.0	1623.1	0	0		0	0	
BC37017	Intake 2PIS	4/15/2020	Field	50.0	1623.1	0	0		0	0	
BC37018	Intake 2PIS	4/19/2020	Field	50.0	1623.1	0	0		0	0	
BC37019	Intake 2PIS	4/20/2020	Field	50.0	1623.1	0	0		0	0	
BC37020	Intake 2PIS	4/21/2020	Field	50.0	1623.1	0	0		0	0	
BC37021	Intake 2PIS	4/22/2020	Field	50.0	1623.1	0	0		0	0	
BC37238	Intake 2PIS	4/26/2020	Field	50.0	1623.1	0	0		0	0	
BC37240	Intake 2PIS	4/28/2020	Field	50.0	1623.1	0	2		0	0	

Unless otherwise noted, all data were generated in accordance with EPA Method 1623/1623.1 and 100% of the filtered volume was examined for each sample.

Reviewed by Mark Long

Date Reviewed: 05/06/20

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Multnomah

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

Portland Water Bureau

ID #: OR 4100657

WTP-A

Month/Year: 04/2020

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)
1	0.39	0.37	0.38	0.37	0.38	0.38	0.39
2	0.38	0.38	0.36	0.38	0.38	0.38	0.38
3	0.37	0.35	0.35	0.35	0.34	0.34	0.37
4	0.34	0.35	0.35	0.36	0.35	0.35	0.36
5	0.35	0.35	0.34	0.34	0.35	0.34	0.35
6	0.35	0.34	0.33	0.32	0.30	0.30	0.35
7	0.31	0.30	0.31	0.31	0.31	0.29	0.31
8	0.29	0.30	0.30	0.29	0.30	0.29	0.30
9	0.30	0.29	0.29	0.29	0.28	0.28	0.30
10	0.29	0.29	0.29	0.28	0.27	0.27	0.29
11	0.28	0.28	0.28	0.27	0.27	0.27	0.28
12	0.28	0.28	0.28	0.28	0.27	0.28	0.28
13	0.28	0.28	0.27	0.28	0.27	0.27	0.28
14	0.28	0.28	0.27	0.28	0.29	0.28	0.29
15	0.28	0.28	0.28	0.30	0.28	0.29	0.30
16	0.30	0.29	0.29	0.29	0.28	0.28	0.30
17	0.29	0.28	0.28	0.27	0.27	0.26	0.29
18	0.27	0.27	0.25	0.25	0.24	0.25	0.27
19	0.25	0.25	0.25	0.25	0.25	0.25	0.25
20	0.27	0.27	0.25	0.26	0.25	0.26	0.27
21	0.28	0.25	0.26	0.25	0.25	0.25	0.28
22	0.25	0.25	0.25	0.25	0.24	0.25	0.25
23	0.25	0.24	0.24	0.24	0.25	0.25	0.25
24	0.25	0.26	0.24	0.24	0.26	0.25	0.26
25	0.26	0.26	0.24	0.24	0.25	0.24	0.26
26	0.26	0.25	0.26	0.24	0.25	0.25	0.26
27	0.25	0.25	0.24	0.24	0.24	0.25	0.25
28	0.27	0.25	0.25	0.24	0.23	0.24	0.27
29	0.24	0.24	0.24	0.24	0.25	0.25	0.25
30	0.25	0.25	0.25	0.25	0.25	0.26	0.26

Slow Sand/Membrane/DE Filtration/Unfiltered			Monthly summary	
95% of daily turbidity readings ≤ 1 NTU? ¹	N/A	CT's met everyday?	Chlorine residual at entry point always ≥ 0.2 mg/L?	Chlorine residual measured in 95% of distribution samples?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes	Yes

¹Filtered systems only

Signature: Anna Vosa
Anna Vosa, P.E.

Date: 5/7/20

OHA Drinking Water Services - Raw Coliform Data (Unfiltered)

Portland Water Bureau

ID#: OR 4100657

Month/Year: 04/2020

Date	Fecal Coliform (CFU/100mL)	Comments
4/1/2020	1	
4/2/2020	1	
4/3/2020	1	
4/6/2020	1	
4/7/2020	<1	
4/8/2020	<1	
4/9/2020	<1	
4/10/2020	<1	
4/13/2020	<1	
4/14/2020	1	
4/15/2020	<1	
4/16/2020	<1	
4/17/2020	<1	
4/18/2020	<1	
4/19/2020	<1	
4/20/2020	<1	
4/21/2020	<1	
4/22/2020	<1	
4/23/2020	<1	
4/24/2020	1	
4/25/2020	1	
4/26/2020	<1	
4/27/2020	<1	
4/28/2020	<1	
4/29/2020	1	
4/30/2020	<1	

Note: Fecal Coliform sampled at active Headworks Raw Water Intake (either 2P or 2PIS)

Six Month Summary:

# of Samples For Fecal Coliform:	174
# of Samples > 20 CFU/100mL:	0
Percent:	0.0%