



Amanda Fritz, Commissioner
 Michael Stuhr, P.E., Administrator
 1120 SW 5th Avenue, Room 600
 Portland, Oregon 97204-1926
 Information: 503-823-7404
 www.portlandoregon.gov/water



DATE: March 13, 2020 WQ 0.10.14.4
TO: Oregon Health Authority, Drinking Water Services

**SUBJECT: Monthly Report for February 2020
 Bilateral Compliance Agreement
 Intake *Cryptosporidium* Results
 PWS # 4100657**

To Whom It May Concern:

Enclosed are results of laboratory analyses for *Cryptosporidium* from the Bull Run raw water intake for February. Monitoring for *Cryptosporidium* at the Bull Run intake is done to comply with the interim measures of the Bilateral Compliance Agreement (Oregon Health Authority, December 18, 2017).

Analyses for *Cryptosporidium* and *Giardia* were performed by the PWB Laboratory (see attached report). Also attached are copies of the monthly turbidity and raw coliform reports previously submitted to OHA in compliance with the SWTR. Results for the reporting month are summarized below:

***Cryptosporidium*, *Giardia*, Turbidity and Fecal Coliforms Data Summary for the Reporting Month**

<i>Cryptosporidium</i> and <i>Giardia</i> Field Samples				<i>Cryptosporidium</i> Recoveries		Fecal Coliforms	Turbidity
No. of Samples	Total Volume (L)	Total No. <i>Cryptosporidium</i> Oocysts	Total No. <i>Giardia</i> Cysts	No. of Matrix Spikes	Average Matrix Spike Recovery (%)	Highest Count (CFU/100 mL)	Highest Reading (NTU)
16	800	12	5	1	74.7	1	0.72

If you have any questions regarding these results, please contact me at 503-823-6135.

Sincerely,

Ann Levy
 Senior Environmental Program Manager

Transmitted: Four pages (including this transmittal memo) emailed to dwp.dmce@state.or.us on this date.



Portland Water Bureau Laboratory
2010 N Interstate Ave, Portland, OR 97227

***Cryptosporidium and Giardia* Laboratory Analysis Report**

<u>Water System Information</u>				<u>Sample Information</u>			
PWS ID:	OR4100657			Collection Month & Year:	Feb. 2020		
PWS Name:	Portland Water Bureau 1900 N Interstate Avenue Portland, Oregon 97227			Report Date:	March 5, 2020		
County:	Multnomah			Monitoring Regime:	Bilateral Compliance Agreement		
				Source Water:	Bull Run Intake - WTP-A		

PWB Sample ID	Loc ID	Sample Collection Date	Sample Type	Sample Volume Filtered (L)	Analysis Method	<i>Cryptosporidium</i>			<i>Giardia</i>		
						No. of Oocysts Spiked	No. of Oocysts Counted	Oocyst Matrix Spike Recovery (%)	No. of Cysts Spiked	No. of Cysts Counted	Cyst Matrix Spike Recovery (%)
BC34819	Intake 2PIS	2/2/2020	Field	50	1623.1	0	2		0	0	
BC34820	Intake 2PIS	2/3/2020	Field	50	1623.1	0	0		0	0	
BC34821	Intake 2PIS	2/3/2020	MS	50	1623.1	99	74	74.7	99	87	87.9
BC34822	Intake 2PIS	2/4/2020	Field	50	1623.1	0	1		0	0	
BC34823	Intake 2PIS	2/5/2020	Field	50	1623.1	0	1		0	2	
BC35077	Intake 2PIS	2/9/2020	Field	50	1623.1	0	0		0	1	
BC35078	Intake 2PIS	2/10/2020	Field	50	1623.1	0	0		0	0	
BC35079	Intake 2PIS	2/11/2020	Field	50	1623.1	0	2		0	0	
BC35080	Intake 2PIS	2/12/2020	Field	50	1623.1	0	2		0	0	
BC35310	Intake 2PIS	2/16/2020	Field	50	1623.1	0	1		0	0	
BC35311	Intake 2PIS	2/17/2020	Field	50	1623.1	0	0		0	0	
BC35312	Intake 2PIS	2/18/2020	Field	50	1623.1	0	0		0	0	
BC35313	Intake 2PIS	2/19/2020	Field	50	1623.1	0	0		0	0	
BC35474	Intake 2PIS	2/23/2020	Field	50	1623.1	0	2		0	1	
BC35475	Intake 2PIS	2/24/2020	Field	50	1623.1	0	1		0	0	
BC35476	Intake 2PIS	2/25/2020	Field	50	1623.1	0	0		0	0	
BC35477	Intake 2PIS	2/26/2020	Field	50	1623.1	0	0		0	1	

Unless otherwise noted, all data were generated in accordance with EPA Method 1623/1623.1 and 100% of the filtered volume was examined for each sample.

Reviewed by Mark Sanj

Date Reviewed: 03/06/20

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: **Multnomah**

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

Portland Water Bureau

ID #: OR 4100657

WTP-A

Month/Year: 02/2020

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)
1	0.51	0.50	0.51	0.51	0.48	0.46	0.51
2	0.45	0.45	0.44	0.43	0.42	0.42	0.45
3	0.43	0.43	0.43	0.43	0.43	0.44	0.44
4	0.45	0.43	0.44	0.45	0.43	0.43	0.45
5	0.43	0.43	0.42	0.43	0.42	0.42	0.43
6	0.41	0.39	0.39	0.39	0.41	0.45	0.45
7	0.48	0.50	0.56	0.56	0.66	0.68	0.68
8	0.69	0.67	0.66	0.65	0.65	0.65	0.69
9	0.67	0.66	0.62	0.64	0.64	0.62	0.67
10	0.63	0.65	0.65	0.65	0.65	0.62	0.65
11	0.59	0.59	0.59	0.64	0.65	0.66	0.66
12	0.65	0.66	0.67	0.66	0.70	0.67	0.70
13	0.66	0.63	0.62	0.62	0.62	0.64	0.66
14	0.65	0.66	0.67	0.72	0.69	0.65	0.72
15	0.65	0.66	0.64	0.65	0.64	0.62	0.66
16	0.66	0.64	0.64	0.64	0.64	0.65	0.66
17	0.61	0.61	0.61	0.60	0.60	0.59	0.61
18	0.58	0.59	0.56	0.59	0.59	0.58	0.59
19	0.56	0.56	0.57	0.56	0.58	0.56	0.58
20	0.56	0.56	0.57	0.56	0.56	0.57	0.57
21	0.56	0.56	0.56	0.56	0.56	0.55	0.56
22	0.54	0.54	0.54	0.54	0.54	0.53	0.54
23	0.54	0.54	0.53	0.50	0.48	0.49	0.54
24	0.50	0.50	0.50	0.50	0.50	0.49	0.50
25	0.49	0.48	0.50	0.49	0.49	0.48	0.50
26	0.48	0.49	0.48	0.47	0.48	0.49	0.49
27	0.49	0.47	0.48	0.48	0.47	0.45	0.49
28	0.49	0.46	0.44	0.45	0.45	0.44	0.49
29	0.42	0.44	0.44	0.42	0.43	0.42	0.44

Slow Sand/Membrane/DE Filtration/Unfiltered			Monthly summary	
95% of daily turbidity readings \leq 1 NTU? ¹	N/A	CT's met everyday?	Chlorine residual at entry point always \geq 0.2 mg/L?	Chlorine residual measured in 95% of distribution samples?
All daily turbidity readings \leq 5 NTU?	Yes	Yes	Yes	Yes

¹Filtered systems only

Signature: 
 Anna Vosa, P.E.

Date: 3/6/20

OHA Drinking Water Services - Raw Coliform Data (Unfiltered)

Portland Water Bureau

ID#: OR 4100657

Month/Year: 02/2020

Date	Fecal Coliform (CFU/100mL)	Comments
2/1/2020	<1	
2/2/2020	<1	
2/3/2020	<1	
2/4/2020	1	
2/5/2020	<1	
2/6/2020	<1	
2/7/2020	1	
2/8/2020	<1	
2/9/2020	1	
2/10/2020	<1	
2/11/2020	1	
2/12/2020	<1	
2/13/2020	1	
2/14/2020	1	
2/15/2020	<1	
2/16/2020	<1	
2/17/2020	1	
2/18/2020	<1	
2/19/2020	<1	
2/20/2020	<1	
2/21/2020	<1	
2/22/2020	<1	
2/23/2020	<1	
2/24/2020	<1	
2/25/2020	<1	
2/26/2020	<1	
2/27/2020	<1	
2/28/2020	<1	
2/29/2020	<1	

Note: Fecal Coliform sampled at active Headworks Raw Water Intake (either 2P or 2PIS)

Six Month Summary:

# of Samples For Fecal Coliform:	182
# of Samples > 20 CFU/100mL:	0
Percent:	0.0%